

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
WHITED BIBLE CAMP (POOL)	REGULAR	2018-07-18	No	3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.E.1	When required, suction grates are not installed and/or approved.	C
				6.H.1	Facility rules for the safe use of the pool or spa not posted in a conspicuous place.	N
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N
WHITED BIBLE CAMP (POOL)	REGULAR	2023-07-26	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				6.E.2	When required, SVRS or other approved system not installed.	C