

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
DOUBLE TREE BY HILTON (POOL)	REGULAR	2019-07-10	No		No Violations	
DOUBLE TREE BY HILTON (POOL)	REGULAR	2022-02-24	No	3.A.2	Public pool or spa establishment owner not retaining a pool or spa supervisor with CPO training and certification or equivalent.	C
				5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
DOUBLE TREE HOTEL (POOL)	NEWOWNER	2023-08-08	No	5.B.2	Flow meter not installed and/or is not accurate.	N