

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
DOWNEAST FAMILY YMCA POOL	REGULAR	2019-11-08	No	3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
DOWNEAST FAMILY YMCA POOL	REGULAR	2024-01-02	No	3.A.2.b	Staff other than the pool or spa supervisor handling sanitizers.	C
				3.A.5	Chemical storage areas not locked at all times.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				6.D.3	Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diameter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diameter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.	C