

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
PENOBSCOT BAY YMCA POOL	REGULAR	2019-01-02	No	6.C.2	Depth markers are not properly positioned to be read from the water side on a vertical pool wall.	C