

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
LEWISTON YWCA POOL	REGULAR	2019-01-17	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C