

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
THE LODGE ON THE COVE (POOL)	REGULAR	2019-09-03	No	4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.D.1	Lifesaving equipment not conspicuously and conveniently on hand at all times by the side of the pool.	C
THE LODGE ON THE COVE (POOL)	REGULAR	2022-09-08	No	8.A.2	All portions of the water distribution system serving the public pool or spa not protected against backflow and back-siphonage and/or water introduced into the public pool or spa is not supplied through an air gap or by another approved method.	C
				5.B.2	Flow meter not installed and/or is not accurate.	N
				3.A.5	Chemical storage areas not locked at all times.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				3.G.4	Material Safety Data Sheets not available for inspection.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C