

| Establishment Name   | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation   | Severity |
|----------------------|------------|------------|-------|------------|--|----------|
| POINT EAST II (POOL) | REGULAR    | 2019-07-25 | No    | 3.G.1      | Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available. | C        |
|                      |            |            |       | 6.D.3      | Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diameter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diameter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.  | C        |
| POINT EAST II (POOL) | REGULAR    | 2019-07-25 | No    | 3.G.1      | Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available. | C        |
| POINT EAST II (POOL) | REGULAR    | 2023-06-13 | No    | 5.B.1      | Pool data sheet not posted and/or does not contain required information.   | N        |
|                      |            |            |       | 3.A.3      | Routine operating procedures not posted and/or available for viewing by the Department.  | C        |
|                      |            |            |       | 6.G.1      | Valves not tagged with metal or rigid plastic tags.  | N        |
|                      |            |            |       | 6.F        | Exposed piping not color coded or color coded correctly.   | N        |
|                      |            |            |       | 6.C.1      | Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.   | C        |
|                      |            |            |       | 5.D.3      | A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.  | N        |
|                      |            |            |       | 6.D.4      | Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.  | C        |