

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
RICHMOND SAUNA	REGULAR	2019-01-25	No	5.C	Pool and/or spa facilities not maintained in a safe and sanitary manner.	N
				5.B.2	Flow meter not installed and/or is not accurate.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.B.1	Rope and float line not present and/or not properly placed.	C
				6.D.5	First aid kit, including barrier protection (gloves and rescue breathing), not available at all times.	C
RICHMOND SAUNA	REGULAR	2019-01-25	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				6.D.5	First aid kit, including barrier protection (gloves and rescue breathing), not available at all times.	C
RICHMOND SAUNA	REGULAR	2022-02-18	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.C.2	Bromine levels not correct.	C
RICHMOND SAUNA	REGULAR	2022-02-18	Yes	5.B.2	Flow meter not installed and/or is not accurate.	N
				3.A.5	Chemical storage areas not locked at all times.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				3.C.2	Bromine levels not correct.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
RICHMOND SAUNA	FOLLOW_UP_FULL	2022-04-08	No	5.B.2	Flow meter not installed and/or is not accurate.	N

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C