

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
ASTICOU INN (POOL)	REGULAR	2019-09-12	No	6.C.9	The transition point of a new pool from the shallow area to the deep area not visually set apart with a 4-inch marked line of contrasting color.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
ASTICOU INN (POOL)	REGULAR	2022-10-04	No	6.F	Exposed piping not color coded or color coded correctly.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C