

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
BAR HARBOR HOTEL - BLUENOSE INN (POOL)	REGULAR	2019-08-20	No		No Violations	
BAR HARBOR HOTEL - BLUENOSE INN (POOL)	REGULAR	2021-10-20	No	6.E.3	Main drains in pools existing or under construction at the time of the effective date of these rules disabled, pool or spa without a main drain constructed after the effective date of these rules unable to show proof of proper filtered and sanitized water and/or pools with main drains as part of the plans do not have two main drains separated by 3 feet on center.	C
BAR HARBOR HOTEL - BLUENOSE INN (POOL)	REGULAR	2021-10-20	No	9.B	The maximum allowable water temperature of 104 F for a public spa exceeded and/or the public spa is not equipped with an accurate thermometer designed for spa use.	C