

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
CLARION HOTEL (POOL)	REGULAR	2019-12-20	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				6.G.2	Procedures and instructions for system operations of valves not referenced by their respective numbers.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				3.C.2	Bromine levels not correct.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.D.1	Lifesaving equipment not conspicuously and conveniently on hand at all times by the side of the pool.	C
CLARION HOTEL (POOL)	REGULAR	2022-08-04	No	5.C	Pool and/or spa facilities not maintained in a safe and sanitary manner.	N
				5.B.2	Flow meter not installed and/or is not accurate.	N
				6.G.2	Procedures and instructions for system operations of valves not referenced by their respective numbers.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C