

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
LIGHTHOUSE CABINS (POOL)	REGULAR	2019-06-19	Yes	4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
				6.C.9	The transition point of a new pool from the shallow area to the deep area not visually set apart with a 4-inch marked line of contrasting color.	C
				6.D.2	Not equipped with a light, strong pole not less than 12 feet long, including a body hook.	C
LIGHTHOUSE CABINS (POOL)	REGULAR	2023-06-22	Yes	6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
				6.D.3	Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diameter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diameter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.	C
				6.D.2	Not equipped with a light, strong pole not less than 12 feet long, including a body hook.	C