

| Establishment Name            | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation  | Severity |
|-------------------------------|------------|------------|-------|------------|---|----------|
| FOOTBRIDGE NORTH HOTEL (POOL) | REGULAR    | 2019-07-08 | No    | 5.B.3      | Disinfectant feeder not installed, not functioning properly, prohibited feeding of a supplemental sanitizer through skimmer basket is allowed, supplemental sanitizer added directly into the pool when in use, supplemental feeding of sanitizer not done in accordance with manufacturers directions, forbidden undissolved sanitizers found in skimmer basket while pool or spa in use, and/or prohibited stabilized chlorine used for indoor pools. | N        |
|                               |            |            |       | 3.G.2      | Appropriate test kit, DPD or FAS-DPD not provided, test kit not capable of testing for free and combined chlorine, pH, total alkalinity, calcium hardness and when used, cyanuric acid, reagents are over one year old and/or prohibited OTO kits and/or test strips are being used.  | C        |
|                               |            |            |       | 6.D.2      | Not equipped with a light, strong pole not less than 12 feet long, including a body hook.   | C        |
|                               |            |            |       | 6.D.3      | Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diameter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diameter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.   | C        |
|                               |            |            |       | 5.D.3      | A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.   | N        |
| FOOTBRIDGE NORTH HOTEL (POOL) | REGULAR    | 2022-09-27 | No    | 3.A.5      | Chemical storage areas not locked at all times.   | N        |
|                               |            |            |       | 5.B.1      | Pool data sheet not posted and/or does not contain required information.  | N        |
|                               |            |            |       | 3.A.3      | Routine operating procedures not posted and/or available for viewing by the Department.   | C        |
|                               |            |            |       | 6.G.1      | Valves not tagged with metal or rigid plastic tags.   | N        |
|                               |            |            |       | 6.F        | Exposed piping not color coded or color coded correctly.  | N        |
|                               |            |            |       | 3.G.4      | Material Safety Data Sheets not available for inspection.   | N        |
|                               |            |            |       | 5.D.3      | A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.   | N        |
|                               |            |            |       | 6.D.4      | Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.   | C        |