

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
GRAND HOTEL LLC (POOL)	REGULAR	2022-11-03	No	6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C