

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|---------------------------|------------|------------|-------|------------|--|----------|
| GREELY HIGH SCHOOL (POOL) | REGULAR | 2020-01-23 | No | 5.B.2 | Flow meter not installed and/or is not accurate. | N |
| | | | | 5.B.1 | Pool data sheet not posted and/or does not contain required information. | N |
| | | | | 3.G.1 | Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available. | C |
| GREELY HIGH SCHOOL (POOL) | REGULAR | 2024-01-17 | No | 8.C.2 | Backwash disposed of on a surface or in a body of water. | C |
| | | | | 3.A.5 | Chemical storage areas not locked at all times. | N |
| | | | | 5.B.1 | Pool data sheet not posted and/or does not contain required information. | N |
| | | | | 3.A.3 | Routine operating procedures not posted and/or available for viewing by the Department. | C |
| | | | | 6.G.2 | Procedures and instructions for system operations of valves not referenced by their respective numbers. | N |