

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
GREELY HIGH SCHOOL (POOL)	REGULAR	2020-01-23	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
GREELY HIGH SCHOOL (POOL)	REGULAR	2024-01-17	No	8.C.2	Backwash disposed of on a surface or in a body of water.	C
				3.A.5	Chemical storage areas not locked at all times.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.2	Procedures and instructions for system operations of valves not referenced by their respective numbers.	N