Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
BEST WESTERN PLUS (POOL)	REGULAR	2022-01-20	Yes	3.A.2	Public pool or spa establishment owner not retaining a pool or spa supervisor with CPO training and certification or equivalent.	С
				5.C	Pool and/or spa facilities not maintained in a safe and sanitary manner.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	С
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	С
				6.D.3	Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diamenter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diamenter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.	С
BEST WESTERN PLUS (POOL)	REGULAR	2023-03-08	No	5.B.3	Disinfectant feeder not installed, not functioning properly, prohibited feeding of a supplemental sanitizer through skimmer basket is allowed, supplemental sanitizer added directly into the pool when in use, supplemental feeding of sanitizer not done in accordance with manufacturers directions, forbidden undissolved sanitizers found in skimmer basket while pool or spa in use, and/or prohibited stabilized chlorine used for indoor pools.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	С
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	С

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
BEST WESTERN PLUS (POOL)	REGULAR	2023-04-14	No		No Violations	
BEST WESTERN PLUS (POOL)	FOLLOW_UP_ FULL	2023-07-18	No	5.A.3	Dressing and sanitary facilities not properly maintained in a sanitary condition, not well drained, not properly constructed of impervious materials, not maintained, do not have separations for each sex, not well lit and/or not properly ventilated.	N
BEST WESTERN PLUS (POOL)	REGULAR	2023-10-20	No	3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	С
BEST WESTERN PLUS (POOL)	FOLLOW_UP_ FULL	2024-01-22	No	3.A.2	Public pool or spa establishment owner not retaining a pool or spa supervisor with CPO training and certification or equivalent.	С
				3.A.2.a	Pool supervisor not properly training staff.	С