

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
PINEHIRST RV PARK (POOL)	REGULAR	2019-07-16	No	5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N
PINEHIRST RV PARK (POOL)	REGULAR	2019-07-16	No	6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N
PINEHIRST RV PARK (POOL)	REGULAR	2019-07-16	No		No Violations	
PINEHIRST RV PARK (POOL)	REGULAR	2019-07-16	No	5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N
PINEHIRST RV PARK (POOL)	REGULAR	2021-07-20	No	3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
PINEHIRST RV PARK (POOL)	REGULAR	2021-07-20	No	4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
PINEHIRST RV PARK (POOL)	REGULAR	2021-07-20	No	4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
PINEHIRST RV PARK (POOL)	REGULAR	2021-07-20	No	3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.C.2	Depth markers are not properly positioned to be read from the water side on a vertical pool wall.	C