

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
RIVER OF LIFE BIBLE CAMP (POOL)	REGULAR	2019-07-09	No	8.A.2	All portions of the water distribution system serving the public pool or spa not protected against backflow and back-siphonage and/or water introduced into the public pool or spa is not supplied through an air gap or by another approved method.	C
				5.B.4.a.i	Circulation system does not meet turnover rate requirements for swimming pools - once every 6 hours.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
RIVER OF LIFE BIBLE CAMP (POOL)	REGULAR	2022-08-02	No	8.A.2	All portions of the water distribution system serving the public pool or spa not protected against backflow and back-siphonage and/or water introduced into the public pool or spa is not supplied through an air gap or by another approved method.	C
				5.B.4.a.i	Circulation system does not meet turnover rate requirements for swimming pools - once every 6 hours.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N