

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
SEA SHELL COTTAGES (POOL)	NEWOWNER	2020-06-05	No	6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
				6.C.2	Depth markers are not properly positioned to be read from the water side on a vertical pool wall.	C
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N