

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
SEABREEZE MOTEL (POOL)	REGULAR	2018-07-19	No	8.A.1	The pool water supply is not adequate, of a safe, sanitary quality, or from a public water system or private source approved by the Department.	C
				5.B.4	Swimming, wading and/or special purpose pools not installed with a system for recirculation and purification of pool water.	N
				3.C	Public pool or spa water is not continuously disinfected by a sanitizer that imparts an easily measured residual.	C
SEABREEZE MOTEL (POOL)	REGULAR	2022-06-29	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.D.3	Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diameter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diameter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.	C