

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
SUPER 8 MOTEL (POOL)	REGULAR	2019-05-16	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
SUPER 8 MOTEL (POOL)	REGULAR	2023-09-25	No	3.A.5	Chemical storage areas not locked at all times.	N