

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|--------------------------|------------|------------|-------|------------|--|----------|
| WAGON WHEEL MOTEL (POOL) | REGULAR | 2019-08-26 | Yes | 3.A.2 | Public pool or spa establishment owner not retaining a pool or spa supervisor with CPO training and certification or equivalent. | C |
| | | | | 3.G.1 | Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available. | C |
| | | | | 3.G.2 | Appropriate test kit, DPD or FAS-DPD not provided, test kit not capable of testing for free and combined chlorine, pH, total alkalinity, calcium hardness and when used, cyanuric acid, reagents are over one year old and/or prohibited OTO kits and/or test strips are being used. | C |
| | | | | 6.C.8 | The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser. | C |
| | | | | 6.C.1 | Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool. | C |
| WAGON WHEEL MOTEL (POOL) | NEWOWNER | 2021-07-02 | No | 6.F | Exposed piping not color coded or color coded correctly. | N |
| | | | | 3.G.1 | Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available. | C |
| | | | | 6.C.8 | The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser. | C |
| | | | | 6.C.1 | Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool. | C |