

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
WATERVILLE GRAND HOTEL (POOL)	REGULAR	2018-05-16	No	6.D.1	Lifesaving equipment not conspicuously and conveniently on hand at all times by the side of the pool.	C
				6.E.2	When required, SVRS or other approved system not installed.	C
				6.E.1	When required, suction grates are not installed and/or approved.	C
WATERVILLE GRAND HOTEL (POOL)	REGULAR	2020-01-13	No		No Violations	
WATERVILLE GRAND HOTEL (POOL)	REGULAR	2022-02-03	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C