

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
WHITE BARN INN (POOL)	REGULAR	2021-08-02	Yes	4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.2	Procedures and instructions for system operations of valves not referenced by their respective numbers.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.G.4	Material Safety Data Sheets not available for inspection.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the tread and 2 inches on the riser.	C
				6.C.3	Depth markers on deck are not within 18 inches of the water edge and/or are not positioned to be read while standing on the deck facing the water.	C
				6.D.3	Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diameter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diameter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.	C
				6.D.2	Not equipped with a light, strong pole not less than 12 feet long, including a body hook.	C
				6.D.1	Lifesaving equipment not conspicuously and conveniently on hand at all times by the side of the pool.	C
				6.H.1	Facility rules for the safe use of the pool or spa not posted in a conspicuous place.	N
				6.D.6	When needed, No Lifeguard on Duty and all children must be supervised in the pool or spa area sign not posted or posted conspicuously.	C
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C
WHITE BARN INN (POOL)	FOLLOW_UP_FULL	2021-08-05	No	6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C