

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
WISCASSET PARKS & RECREATION (POOL)	REGULAR	2019-01-15	No	5.A.3	Dressing and sanitary facilities not properly maintained in a sanitary condition, not well drained, not properly constructed of impervious materials, not maintained, do not have separations for each sex, not well lit and/or not properly ventilated.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N