

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
THE EXECUTIVE MOTEL (POOL)	REGULAR	2019-06-21	No	5.B.3	Disinfectant feeder not installed, not functioning properly, prohibited feeding of a supplemental sanitizer through skimmer basket is allowed, supplemental sanitizer added directly into the pool when in use, supplemental feeding of sanitizer not done in accordance with manufacturers directions, forbidden undissolved sanitizers found in skimmer basket while pool or spa in use, and/or prohibited stabilized chlorine used for indoor pools.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				3.C.1	Free chlorine levels not correct and/or stabilized chlorine used in indoor pool.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
THE EXECUTIVE MOTEL (POOL)	REGULAR	2022-08-31	No	5.B.3	Disinfectant feeder not installed, not functioning properly, prohibited feeding of a supplemental sanitizer through skimmer basket is allowed, supplemental sanitizer added directly into the pool when in use, supplemental feeding of sanitizer not done in accordance with manufacturers directions, forbidden undissolved sanitizers found in skimmer basket while pool or spa in use, and/or prohibited stabilized chlorine used for indoor pools.	N
				6.F	Exposed piping not color coded or color coded correctly.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C