

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
COLD RIVER CAMPGROUND (POOL)	REGULAR	2019-07-16	No	4.C.1.a	Gate latch not at correct height.	C
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C
COLD RIVER CAMPGROUND (POOL)	NEWOWNER	2021-06-15	No	3.C.1	Free chlorine levels not correct and/or stabilized chlorine used in indoor pool.	C
				6.D.4	Location of the nearest telephone not posted with dialing instructions in the immediate vicinity of the public pool or spa and/or the telephone does not have posted names and numbers of the nearest available police, fire, ambulance service and/or rescue unit.	C
COLD RIVER CAMPGROUND (POOL)	REGULAR	2022-06-15	No		No Violations	