

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
TWIN PONDS LODGE (POOL)	REGULAR	2019-01-02	No	5.C	Pool and/or spa facilities not maintained in a safe and sanitary manner.	N
				5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C
TWIN POND LODGE (POOL)	NEWOWNER	2022-07-20	No	5.B.1	Pool data sheet not posted and/or does not contain required information.	N