

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
CAMP PIERCE WEBBER (POOL)	REGULAR	2019-07-01	No	5.C	Pool and/or spa facilities not maintained in a safe and sanitary manner.	N
				5.A.3	Dressing and sanitary facilities not properly maintained in a sanitary condition, not well drained, not properly constructed of impervious materials, not maintained, do not have separations for each sex, not well lit and/or not properly ventilated.	N
				4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
				5.D.3	A sign instructing users of the pool or spa to shower prior to entering the public pool or spa is not posted.	N
CAMP PIERCE WEBBER (POOL)	FOLLOW_UP_FULL	2019-07-19	No	5.C	Pool and/or spa facilities not maintained in a safe and sanitary manner.	N
				4.C.1	Pedestrian access gate not self-closing, self-latching, opening outward, or can not accommodate a lock.	C
				5.B.4.a.i	Circulation system does not meet turnover rate requirements for swimming pools - once every 6 hours.	N
				5.B.3	Disinfectant feeder not installed, not functioning properly, prohibited feeding of a supplemental sanitizer through skimmer basket is allowed, supplemental sanitizer added directly into the pool when in use, supplemental feeding of sanitizer not done in accordance with manufacturers directions, forbidden undissolved sanitizers found in skimmer basket while pool or spa in use, and/or prohibited stabilized chlorine used for indoor pools.	N
				5.B.2	Flow meter not installed and/or is not accurate.	N
				6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
CAMP PIERCE WEBBER (POOL)	REGULAR	2021-07-30	No	8.A.2	All portions of the water distribution system serving the public pool or spa not protected against backflow and back-siphonage and/or water introduced into the public pool or spa is not supplied through an air gap or by another approved method.	C