

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|--|------------|------------|-------|------------|--|----------|
| SUGARLOAF SPORTS & FITNESS CENTER (POOL) | REGULAR | 2018-12-13 | No | 5.B.2 | Flow meter not installed and/or is not accurate. | N |
| | | | | 6.F | Exposed piping not color coded or color coded correctly. | N |