

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HYATT PLACE PORTLAND-OLD PORT (POOL)	REGULAR	2019-12-27	Yes	3.A.2	Public pool or spa establishment owner not retaining a pool or spa supervisor with CPO training and certification or equivalent.	C
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				3.C.1	Free chlorine levels not correct and/or stabilized chlorine used in indoor pool.	C
				6.D.3	Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diameter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diameter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.	C
				6.D.5	First aid kit, including barrier protection (gloves and rescue breathing), not available at all times.	C
HYATT PLACE PORTLAND-OLD PORT (POOL)	FOLLOW_UP_FULL	2019-12-30	No		No Violations	
HYATT PLACE PORTLAND-OLD PORT (POOL)	REGULAR	2022-07-27	No	6.G.2	Procedures and instructions for system operations of valves not referenced by their respective numbers.	N
				3.C.1	Free chlorine levels not correct and/or stabilized chlorine used in indoor pool.	C
				6.D.5	First aid kit, including barrier protection (gloves and rescue breathing), not available at all times.	C