

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
MADAWASKA CAMPGROUND	REGULAR	2019-08-23	No	1.B	License not posted.	
				3.A.4	A current copy of the water analysis is not posted in the park in view of the public and/or the water has not been tested and shown to be satisfactory before the campground opens for the season.	
MADAWASKA CAMPGROUND	REGULAR	2023-08-02	No	1.B	License not posted.	
				7.D.1	Individual water services are improperly located, designed, protected, or sized.	
				3.A.4	A current copy of the water analysis is not posted in the park in view of the public and/or the water has not been tested and shown to be satisfactory before the campground opens for the season.	
				3.F.6	The building is not free of objectionable odors.	
				3.A.1	Hot and cold water not provided.	