

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|--------------------|------------|------------|-------|------------|--|----------|
| CORNELIA WARE POOL | REGULAR | 2018-08-21 | No | 5.B.1 | Pool data sheet not posted and/or does not contain required information. | N |
| | | | | 6.G.1 | Valves not tagged with metal or rigid plastic tags. | N |
| | | | | 3.G.1 | Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available. | C |
| | | | | 6.C.2 | Depth markers are not properly positioned to be read from the water side on a vertical pool wall. | C |