

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HILLTOP CAMPGROUND (POOL)	REGULAR	2019-07-31	No	6.F	Exposed piping not color coded or color coded correctly.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
HILLTOP CAMPGROUND (POOL)	REGULAR	2020-06-25	No		No Violations	