

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
PORTLAND REGENCY HOTEL & SPA (POOL)	REGULAR	2018-07-18	No	5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				3.C.3	pH not correct.	C
				3.C.2	Bromine levels not correct.	C
PORTLAND REGENCY HOTEL & SPA (POOL)	REGULAR	2019-12-30	Yes	3.A.2	Public pool or spa establishment owner not retaining a pool or spa supervisor with CPO training and certification or equivalent.	C
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				3.C.3	pH not correct.	C
				3.C.2	Bromine levels not correct.	C
PORTLAND REGENCY HOTEL & SPA (POOL)	REGULAR	2022-07-27	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C