

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
RESIDENCE INN BY MARRIOTT (POOL)	REGULAR	2018-07-18	No	3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
RESIDENCE INN BY MARRIOTT (POOL)	REGULAR	2019-10-11	No	6.G.2	Procedures and instructions for system operations of valves not referenced by their respective numbers.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				3.C.2	Bromine levels not correct.	C
RESIDENCE INN BY MARRIOTT (POOL)	REGULAR	2022-06-29	No	6.G.1	Valves not tagged with metal or rigid plastic tags.	N
RESIDENCE INN BY MARRIOTT (POOL)	REGULAR	2023-09-06	No	6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				3.C.2	Bromine levels not correct.	C