

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
BAR HARBOR WOODLANDS KOA (POOL)	REGULAR	2018-08-02	No	3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				3.B.1	The recirculation system is not operated continuously, the water clarity is such that the main drain is not visible from the deck of the pool or spa, the pool or spa water is not clean and clear due to improper operation, there is improper operation of the recirculation and/or purification system, and/or a pool or spa, closed by the Department, has reopened without specific written approval by the Department.	C
BAR HARBOR WOODLANDS KOA (POOL)	REGULAR	2018-08-03	No		No Violations	