

| Establishment Name          | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation  | Severity |
|-----------------------------|------------|------------|-------|------------|---|----------|
| RED APPLE CAMPGROUND (POOL) | REGULAR    | 2021-07-06 | No    | 6.C.1      | Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.  | C        |
|                             |            |            |       | 6.D.3      | Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diameter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diameter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less. | C        |
| RED APPLE CAMPGROUND (POOL) | REGULAR    | 2022-07-21 | No    | 3.A.3      | Routine operating procedures not posted and/or available for viewing by the Department.   | C        |
|                             |            |            |       | 6.F        | Exposed piping not color coded or color coded correctly.  | N        |