

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HOMEWOOD SUITES BY HILTON AUGUSTA (POOL)	REGULAR	2021-01-13	No	6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.F	Exposed piping not color coded or color coded correctly.	N