

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HAMPTON INN (POOL)	REGULAR	2018-10-16	No		No Violations	
HAMPTON INN (POOL)	REGULAR	2022-10-19	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
HAMPTON INN (POOL)	REGULAR	2022-11-10	No		No Violations	