

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
SWANS FALLS CAMPGROUND	REGULAR	2019-09-03	No	1.B	License not posted.	
				7.D.1	Individual water services are improperly located, designed, protected, or sized.	
				3.A.4	A current copy of the water analysis is not posted in the park in view of the public and/or the water has not been tested and shown to be satisfactory before the campground opens for the season.	
				3.A	Unacceptable water supply.	
				3.B.2	Liquid waste is not being discharged into a suitable container and/or is being discharged onto the ground surface.	
				3.F.5	The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair.	
				3.A.1	Hot and cold water not provided.	
SWANS FALLS CAMPGROUND	REGULAR	2023-09-08	No	1.B	License not posted.	
				7.D.1	Individual water services are improperly located, designed, protected, or sized.	
				3.B.2	Liquid waste is not being discharged into a suitable container and/or is being discharged onto the ground surface.	
				3.A.1	Hot and cold water not provided.	