

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
LOCKLINS CAMPGROUND	REGULAR	2019-09-05	No	8.A.4	Plans submitted did not include specifications of the proposed park or area showing the number and location of RV and tenting sites.	
				3.F.5	The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
				5.A.	Garbage and rubbish not kept in durable insect proof containers that do not leak and do not absorb liquids.	