

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|------------------------------|------------|------------|-------|------------|--|----------|
| SMUGGLERS COVE INN | REGULAR | 2019-06-06 | No | 6.C.8 | The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser. | C |
| | | | | 6.B.1 | Rope and float line not present and/or not properly placed. | C |
| SMUGGLERS COVE INN (POOL) | NEWOWNER | 2021-05-26 | No | 5.B.1 | Pool data sheet not posted and/or does not contain required information. | N |
| | | | | 3.A.3 | Routine operating procedures not posted and/or available for viewing by the Department. | C |
| | | | | 6.G.1 | Valves not tagged with metal or rigid plastic tags. | N |
| | | | | 6.F | Exposed piping not color coded or color coded correctly. | N |
| BLUE DIAMOND BOOTHBAY (POOL) | NEWOWNER | 2023-05-18 | No | | No Violations | |