

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
TOWN OF MAPLETON	REGULAR	2019-07-10	No	5.B.4.a.ii	Circulation system does not meet turnover rate requirements for wading pools - once every hour.	N
				5.B.4.a.i	Circulation system does not meet turnover rate requirements for swimming pools - once every 6 hours.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N