

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|------------------------------|------------|------------|-------|------------|--|----------|
| 2 VILLAGE SQUARED INN (POOL) | REGULAR | 2019-06-25 | No | 5.B.1 | Pool data sheet not posted and/or does not contain required information. | N |
| | | | | 6.G.1 | Valves not tagged with metal or rigid plastic tags. | N |
| | | | | 6.F | Exposed piping not color coded or color coded correctly. | N |
| 2 VILLAGE SQUARE INN (POOL) | REGULAR | 2023-06-07 | No | 6.G.1 | Valves not tagged with metal or rigid plastic tags. | N |
| | | | | 3.G.2 | Appropriate test kit, DPD or FAS-DPD not provided, test kit not capable of testing for free and combined chlorine, pH, total alkalinity, calcium hardness and when used, cyanuric acid, reagents are over one year old and/or prohibited OTO kits and/or test strips are being used. | C |