

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
THE BARN	REGULAR	2019-08-07	No	5-203.14	Backflow prevention device not installed when required.	C