

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
ALCHIMIA	REGULAR	2020-01-22	No	5-202.13	Air gap required.	C
				5-203.13	Inadequate number of service sinks.	N