

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
FAYETTE FAMILY CAMPGROUND (POOL)	REGULAR	2020-08-14	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the tread and 2 inches on the riser.	C
FAYETTE FAMILY CAMPGROUND (POOL)	REGULAR	2022-08-11	No	5.B.4.a.i	Circulation system does not meet turnover rate requirements for swimming pools - once every 6 hours.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				3.B.1	The recirculation system is not operated continuously, the water clarity is such that the main drain is not visible from the deck of the pool or spa, the pool or spa water is not clean and clear due to improper operation, there is improper operation of the recirculation and/or purification system, and/or a pool or spa, closed by the Department, has reopened without specific written approval by the Department.	C
				3.C.1	Free chlorine levels not correct and/or stabilized chlorine used in indoor pool.	C