

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
UNIVERSITY OF MAINE AT FARMINGTON (POOL)	REGULAR	2020-08-26	No	5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.A.3	Routine operating procedures not posted and/or available for viewing by the Department.	C
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.C.2	Depth markers are not properly positioned to be read from the water side on a vertical pool wall.	C